



THE KOLKATA MUNICIPAL CORPORATION
OFFICE OF THE EXECUTIVE ENGINEER
BOROUGH NO. – VIII
172/5, R.B. AVENUE, KOL-29.

From :- The Executive Engineer
Borough No.-VIII
172/5, R.B. Avenue, Kol-29.

Date: 08.08.23

To:- Mrs. Manween Rajpal
(Executive Secretary/Manager)
Gurbachan Singh Sondhi Girls' School,
65, Pratapaditya Road, Kol-26.

A joint inspection has been made by the officials of this department on dated 24/07/2023 at your G.S.S. High School and found the sanitary condition of the mentioned school is more or less in good condition. Sewer condition of K.M.C. is well and good. This is for your information please.

AD
ABCY
08.08.23

to
8/8/23
Executive Engineer, VIII
EXECUTIVE ENGINEER
BOROUGH-VIII, K.M.C.



THE KOLKATA MUNICIPAL CORPORATION
CENTRAL LABORATORY (WATER SECTION), HEALTH
1A, HOGG STREET, KOLKATA - 700087

WATER TEST REPORT

Name of Client and Address : Gurubachan Singh Sondhi Girls' School 65, Pratapaditya Road, Kolkata-700026	Sample Type	Drinking water
	Sample Collected From	Water Purifier at Kitchen
	Source	KMC supply
	Sample Collected On	27/07/2023
	Method of Sampling	IS:3025 (Part 1)

Water Analysis Result

Microbiological Analysis

Sl. No.	Characteristic	Limit as per Drinking Water Standard: IS:10500, 2012	Test Method	Result
1.	Total Coliform Count/100ml	Not Detectable	IS 15185-2016	Not Detected
2.	Fecal Coliform Count/100ml	Not Detectable	IS 15185-2016	Not Detected

REMARKS: Water is potable in respect to the above parameters of IS 10500:2012

Dated : 31.07.23

[Handwritten Signature]
Analyst
31/07/23
ANALYST
Central Laboratory
CENTRAL LABORATORY, HEALTH
The Kolkata Municipal Corporation
The Kolkata Municipal Corporation



OFFICE OF EXECUTIVE ENGINEER W/S

KOLKATA MUNICIPAL CORPORATION
WATER SUPPLY DEPARTMENT (WEST)
212, RASHBEHARI AVENUE, KOLKATA 700019

Ref. No. EEWS(W)/15/2023-24

Date : 27.07.2023

To
The Executive Secretary/Manager,
G.S.S. Girl's School,
65, Pratapaditya Road,
Kolkata 700026

Sub: Certificate for supplying Water of KMC at Pre. No. 65, Pratapaditya Road, Kolkata - 700026

Sir/Madam,

After departmental inspection it has been observed that supply of F.W. pressure is normal in your school premises and it has been certified that our supply of filter water is used for drinking purpose, but your internal distribution system including underground and overhead reservoir is to be cleaned every week to avoid contamination on hygienic point of view.

yours sincerely,

[Handwritten Signature]
27/07/23

[Handwritten Signature]
27.07.23

Consulting Engineer
Water Supply Department
Kolkata Municipal Corporation

Executive Engineer W/S
KMC